



WASLIX
CLEARLY CLEAN WATER

Mineral Descaler: Estimated Spacing Requirements

Descaler.Waslix.com

| Support@Waslix.com

| 412-848-5058

Pipe Diameter (inch)	Model	Impuse Bands	Band Length (foot)	Spacing Required (inch)	Spacing Required (foot)
1 1/2	V3000	2	3.3	7	0.6
1 1/2	V5000	2	6.5	13	1.1
1 1/2	S10	2	9.8	40	3.3
2	V5000	2	6.5	10	0.8
2	S10	2	9.8	30	2.5
2	S25	4	9.8	60	5.0
2	S50	4	13.1	80	6.7
3	S10	2	9.8	20	1.6
3	S25	4	9.8	40	3.3
3	S50	4	13.1	53	4.4
3	S100	6	13.1	79	6.6
3	S150	6	26.2	158	13.2
4	S25	4	9.8	30	2.5
4	S50	4	13.1	40	3.3
4	S100	6	13.1	60	5.0
4	S150	6	26.2	120	10.0
4	S250	8	32.8	200	16.7
5	S50	4	13.1	32	2.7
5	S100	6	13.1	48	4.0
5	S150	6	26.2	96	8.0
5	S250	8	32.8	160	13.4

Pipe Diameter (inch)	Model	Impuse Bands	Band Length (foot)	Spacing Required (inch)	Spacing Required (foot)
6	S100	6	13.1	40	3.3
6	S150	6	26.2	80	6.7
6	S250	8	32.8	134	11.2
6	S350	8	65.6	267	22.3
8	S150	6	26.2	60	5.0
8	S250	8	32.8	100	8.4
8	S350	8	65.6	200	16.7
8	S500	10	98.4	376	31.3
10	S250	8	32.8	80	6.7
10	S350	8	65.6	160	13.4
10	S500	10	98.4	301	25.1
12	S350	8	65.6	134	11.2
12	S500	10	98.4	251	20.9
14	S350	8	65.6	113	9.4
14	S500	10	98.4	212	17.7
16	S500	10	98.4	186	15.5
20	S500	10	98.4	150	12.5
20	X-PRO 1	12	82	301	25.1
24	X-PRO 1	12	82	251	20.9
26	X-PRO 1	12	82	228	19.0
28	X-PRO 1	12	82	212	17.7
30	X-PRO 1	12	82	198	16.5
32	X-PRO 2	12	164	371	30.9
34	X-PRO 2	12	164	350	29.1
36	X-PRO 2	12	164	331	27.6
38	X-PRO 2	12	164	313	26.1
40	X-PRO 2	12	164	298	24.8